


VERIFICATION OF LVD COMPLIANCE

Applicant: Wenzhou Shuguang Fuse Co., Ltd.
No.431, Daxing West Road, Liushi Town, Yueqing City, Zhejiang
Province P.R.China

Manufacturer: Wenzhou Shuguang Fuse Co., Ltd.
No.431, Daxing West Road, Liushi Town, Yueqing City, Zhejiang
Province P.R.China

Trade Name: 

Product Description: 33KV Cutout Fuse, 11KV Cutout Fuse, Fuse Links 33KV T type,
Fuse Links 11KV K Type and T Type, DHR-400 Fuse Base and
J-82 Fuse Links

Model No: See Annex A.

Technical Data: See Annex A.

Sufficient samples of the product have been tested and found to be in conformity with
Test Standard: IEC 60282-2:2008, EN 60282-1:2009,
EN 60269-1:2007+A2:2014.


As shown in the
Test Report Number(s): TLZJ1601056961
Date of issue: January 8th, 2016

Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of tests, performed by laboratory of Global Testing Services Co., Ltd on sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Low Voltage Directive 2014/35/EU. The CE marking as shown below can be affixed, under the responsibility of the manufacturer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives. The affixing of the CE marking presumes in addition that conditions the conditions in annexes III and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

For and on behalf of
Global Testing Services Co., Ltd




Global Testing Services Co., Ltd
E-mail: info@gts-lab.com <http://www.gts-lab.com>
No. 968 Meilong West Road, Minhang District, Shanghai, 201104 China

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.

Annex A

Product	Model No	Parameter
33KV Cutout Fuse	/	33KV 100A
11KV Cutout Fuse	/	11KV 100A
Fuse Link 33KV T type	T	40A、50A、80A、100A
Fuse Links 11KV K Type	K	4A、6A、10A、16A、25A、40A、 50A、80A、100A
Fuse Links 11KV T Type	T	4A、6A、10A、16A、25A、40A、 50A、80A、100A
Low-Voltage H.R.C Fuse Base	DHR-400	/
Low Voltage H.R.C Fuse Links	J-82	415V 80-400A

Note: The certificate includes two pages in total. The content in Page 2 is effective to connect to the Page 1.



Global Testing Services Co., Ltd
E-mail: info@gts-lab.com <http://www.gts-lab.com>
No. 968 Meilong West Road, Minhang District, Shanghai, 201104 China

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.